

General Information
(see reverse for instructions)

| | | | | | |
|---|---|-------------------------|-----------------------------|------------------------|--------------|
| Name of Project | Franklin Hills Estates & Country Club | CGP Tracking No. | IR #20-10 | Inspection Date | 1/27-28/2021 |
| Inspector Name, Title & Contact Information | Inspector: David C. McKay, P.E. | | Reviewer: David McKay, P.E. | | |
| Present Phase of Construction | Phase 1 | | | | |
| Inspection Location (if multiple inspections are required, specify location where this inspection is being conducted) | Areas of Concern as defined at site walk with wetlands commission | | | | |
| <p>Inspection Frequency (Note: you may be subject to different inspection frequencies in different areas of the site. Check all that apply.)</p> <p>Standard Frequency: <input type="checkbox"/> Weekly <input type="checkbox"/> within 24 hours of a 0.5" rain</p> <p>Increased Frequency: <input type="checkbox"/> Every 7 days and within 24 hours of a 0.5" rain (for areas of sites discharging to sediment or nutrient-impaired waters or to waters designated as Tier 2, Tier 2.5, or Tier 3)</p> <p>Reduced Frequency:</p> <ul style="list-style-type: none"> - <input type="checkbox"/> Once per month (for stabilized areas) - <input checked="" type="checkbox"/> Once per month and within 24 hours of a 0.5" rain (for arid, semi-arid, or drought-stricken areas during seasonally dry periods or during drought) - <input type="checkbox"/> Once per month (for frozen conditions where earth-disturbing activities are being conducted) | | | | | |
| <p>Was this inspection triggered by a 0.5" storm event? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If yes, how did you determine whether a 0.5" storm event has occurred?</p> <p><input type="checkbox"/> Rain gauge on site <input type="checkbox"/> Weather station representative of site. Specify weather station source: Weather Underground – Franklin</p> <p>Total rainfall amount that triggered the inspection (in inches): No rainfall, inspections were completed to verify erosion and sedimentation control repairs were completed.</p> | | | | | |
| <p>Unsafe Conditions for Inspection</p> <p>Did you determine that any portion of your site was unsafe for inspection per CGP Part 4.1.5? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If "yes", complete the following:</p> <ul style="list-style-type: none"> - Describe the conditions that prevented you from conducting the inspection in this location: - Location(s) where conditions were found: | | | | | |



Condition and Effectiveness of Erosion and Sediment (E&S) Controls

| Type/Location of E&S Control | Repairs or Other Maintenance Needed?* | Corrective Action Required?* | Date on Which Maintenance or Corrective Action First Identified? | Notes |
|--|---|---|--|--|
| 1. Main Entry Water Crossing (Northerly of 3 rd Hole Green) | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | Stone check dam immediately upgradient of crossing has been replaced and has ample storage capacity (Photo 1). Stone check dam in trail leading down to crossing has been replaced and has ample storage capacity (Photo 2). An additional check dam has been added. |
| 2. 15 th Green Sediment Barriers | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | Downgradient stone check dam remains in good condition. Sediment fence along the cart path and along the tree line have been repaired and reinforced with stone check dams. Intermediate sediment fence has been re-staked. (Photo 3). Sediment fence rows and staked hay bales in south end have been repaired and eroded area has been stabilized with stone. (Photo 4). |
| 3. 15 th Fairway Sediment Barriers | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | Stone check dams, stone apron are in good condition and functioning as intended. Sediment fence has been repaired and reinforced with additional stone check dam (Photo 5). |
| 4. Construction Entrance (Westerly of Proposed Maintenance Road) | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | Stone check dam and water bar across construction entrance are in good condition and functioning. Staked hay bales and sediment fence are deteriorating and have been removed from flow path (Photo 6). Diversion swale excavated to downgradient drainage structure does not show signs of erosion. Stone check dams should be added to new swale if erosion occurs. |
| 5. 7 th Hole Fairway Hillside | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | Check dams across 7 th Hole fairway are in good condition overall and functioning as intended (Photo 7). Sediment fence has been repaired and reinforced with additional stone check dams. |
| 6. 11 th Hole Tee Box Area | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | Sediment fence row across path by 11 th Hole tee box has been repaired and reinforced with an additional hay bale check dam (Photo 8). Stone check dam has been replaced. |
| 7. 14 th Hole Green Sediment Barriers | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | Sediment fence row at tree line has been reinforced with an additional check dam (Photo 9). Additional stone check dams have been added upgradient of the sediment fence. |
| 8. Created Wetlands Outlet | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | No repairs required. |

* **Note:** The permit differentiates between conditions requiring repairs and maintenance, and those requiring corrective action. The permit requires maintenance in order to keep controls in effective operating condition and requires repairs if controls are not operating as intended. Corrective actions are triggered only for specific, more serious conditions, which include: 1) A required stormwater control was never installed, was installed incorrectly, or not in accordance with the requirements in Part 2 and/or 3; 2) You become aware that the stormwater controls you have installed and are maintaining are not effective enough for the discharge to meet applicable water quality standards or applicable requirements in Part 3.1; 3) One of the prohibited discharges in Part 2.3.1 is occurring or has occurred; or 4) EPA requires corrective actions as a result of a permit violation found during an inspection carried out under Part 4.2. If a condition on your site requires a corrective action, you must also fill out a corrective action form found at www.epa.gov/npdes/stormwater/swppp. See Part 5 of the permit for more information.



Condition and Effectiveness of Pollution Prevention

| Type/Location of P2 Practices | Repairs or Other Maintenance Needed?* | Corrective Action Required?* | Date on Which Maintenance or Corrective Action First Identified? | Notes |
|-------------------------------|--|--|--|-------|
| 1. | <input type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No | | |
| 2. | <input type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No | | |
| 3. | <input type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No | | |
| 4. | <input type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No | | |
| 5. | <input type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No | | |
| 6. | <input type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No | | |
| 7. | <input type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No | | |
| 8. | <input type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No | | |

* Note:



Stabilization of Exposed Soil

| Stabilization Area | Stabilization Method | Have You Initiated Stabilization? | Notes |
|--|---|--|---|
| 1. Construction Access Drive | Plans - Anti-tracking pad Existing - Water bar at site entrance | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A | There was little flow in the swale during the inspection with no evidence of erosion. Add stone check dams to swale if erosion occurs. |
| 2. 7 th Hole Fairway Hillside | Plans – Multiple rows of silt fence Existing – Series of stone check dams and silt fence | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A | Area is stabilized at this time. Stone check dams are in good condition. Sediment fence rows and staked hay bales have been repaired and reinforced with stone check dams. |
| 3. 15 th Hole Fairway | Plans – Silt fence and stone check dam Existing – Series of stone check dams and silt fence at limits of wooded area to the west | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A | Erosion at the southern limit of the green has been stabilized with stone. Stone check dams and sediment fence rows have been repaired. Lower rows of sediment fence have been reinforced with stone check dams. Intermediate sediment fence through the sapling stand has been repaired. |
| 4. 11 th Hole Tee Box Area | Plans – Silt fence and diversion channel Existing – Single row of silt fence across path and one stone check dam | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A | Sediment fence has been repaired and reinforced with a hay bale check dam. An additional stone check dam has been added. |



Description of Discharges

Was a stormwater discharge or other discharge occurring from any part of your site at the time of the inspection? Yes No

If "yes", provide the following information for each point of discharge:

| Discharge Location | Observations |
|------------------------------------|---|
| Swale by Construction Access Drive | Low flow. |
| Main Entry Water Crossing | Clear flow contained within stream banks. |
| Created Wetlands Outlet | Clear flow into channel. |

Certification and Signature by Permittee

(see reverse for instructions)

"I certify that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Signature of Permittee or

"Duly Authorized Representative":



Date: 1/28/2021

Printed Name and Affiliation:

David McKay, P.E. for Boundaries, LLC






Photo 1: Stone check dam immediately upgradient of main entry water crossing has been repaired.




Photo 2: Stone check dam in path leading to water crossing has been repaired and an additional check dam has been added.

Note: All photos were taken between 1/26 and 1/28 as repairs were completed, red arrows denote photo location and blue lines denote item of concern.




Photo 3: Sediment fence has been repaired and reinforced with stone check dams.




Photo 4: Staked hay bales have been replaced and eroded area has been stabilized with stone.




Photo 5: Stone check dams and staked hay bales are in good condition. Sediment fence has been repaired and an additional stone check dam has been added.




Photo 6: Recently constructed swale carrying flow to downgradient drainage structure. No signs of erosion in swale.




Photo 7: Stone check dams across the 7th hole fairway hillside remain in good condition. Sediment fence rows and hay bales have been repaired and reinforced with stone check dams.




Photo 8: Sediment fence row across 11th hole tee box area has been repaired and stone check dam upgraded. A hay bale check dam has been added upgradient of the sediment fence.




Photo 9: Sediment fence has been repaired and additional stone check dams added to disrupt flows.